

Approval Number 2012569
Test Report: J-00367579 & J-00367574



Water Regulations Approval Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

20th December 2021

SHK Polymers Industries
Harikrishna House, Plot No. - 139/1, Phase - 1,
Opp. Patel Alloy Steel Ltd.
GIDC,
Vatva,
Ahmedabad - 382 445,
Gujurat,
India

**WATER REGULATIONS APPROVAL SCHEME LTD. (WRAS)
MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

POLYPROPYLENE- COMPONENTS.

5260

'SHK Aqua Fitting'. Green coloured, injection moulded PP-R fitting. For use with water up to 85°C.

APPROVAL NUMBER: 2012569
APPROVAL HOLDER: SHK POLYMERS INDUSTRIES

The Scheme reserves the right to review approval.
Approval 2012569 is valid between December 2020 and December 2025

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wrasapprovals.co.uk/approvals-directory/

Yours Faithfully

A handwritten signature in blue ink, appearing to read 'Ian Hughes', with a stylized flourish at the end.

Ian Hughes
WRAS Approvals Manager